

PO Box 149104 | Austin, TX 78714 | 1-800-578-4677 | tdi.texas.gov

Product Evaluation

WIN686 | 0419

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 1-800-248-6032.

Evaluation ID: WIN-686	Effective Date:	April 1, 2019
	Re-evaluation Date:	March 2023

Product Name: Aluminum Clad Wood French Casement Window, Fin Installation, Non-Impact Resistant

Manufacturer: Lincoln Wood Products, Inc 1400 West Taylor Street Merrill, Wisconsin 54452 (715) 536-2461

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Aluminum Clad Wood	LC-PG25 60 x 78-C	+25 / -25 psf
Ť	French Casement Window	LC-PG25 00 X 78-C	+237-23 psi

Product Dimensions:

System	Overall Size	Sash Size
1	60" x 78"	28.69" x 76.25"

Product Identification (Certification Label on Window):

System		
	Certification agency	AAMA
1	Manufacturer's name or code name	LN-1
1 ¹	Product name	Clad French Casement
	Test standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

Impact Resistance:

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

System		
	Type of Installation	Nail Fin Installation
	Wall Framing	Spruce-Pine-Fir dimension lumber
	Fasteners	Minimum 2" smooth shank roofing nails with a
1		0.12" (11-gauge) shaft diameter and a 0.39" head
	Fastener Location/Spacing	Approximately 7" from each corner and 7" on
		center along the perimeter
	Fastener Penetration	Minimum of 1-1/2" into the wall framing

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.