

TEXAS DEPARTMENT OF INSURANCE

Engineering Services Program / MC 103-3A 333 Guadalupe Street P.O. Box 149104 Austin, Texas 78714-9104
 Phone No. (512) 322-2212 Fax No. (512) 463-6693

PRODUCT EVALUATION
 WIN-978

Effective Date: October 1, 2013
 Reevaluation Date: **June 2014**

The following product has been evaluated for compliance with the wind loads specified in the **International Residential Code (IRC)** and the **International Building Code (IBC)**.

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

Windquest V707 Vinyl Double Hung Windows, Impact Resistant, manufactured by

Kolbe & Kolbe Millwork Co., Inc.
 1323 South Eleventh Avenue
 Wausau, Wisconsin 54401
 Telephone: (715) 842-5666

General Description:

System	Description	Label Rating	Design Pressure Rating (psf)	HallMark Certification
1	Windquest V707 Vinyl Double Hung Window	LC-PG70 52 x 75 – H H-LC70 52 x 75 Missile Level D	+70/-70	416-H-952.00 416-H-952.01 416-H-953.00 416-H-953.01 416-H-954.00 416-H-954.01 416-H-955.00 416-H-955.01 416-H-955.02

Product Dimensions:

System	Overall Size	Top Operating Sash Size	Bottom Operating Sash Size
1	52.00" x 75.00"	48.13" x 36.56"	49.25" x 36.63"

Product Identification (Certification Agency Label on Window):

System	Product Identification	
1	Certification Agency	WDMA
	Manufacturer's Name or Code Name	Kolbe & Kolbe Millwork, Co., Inc.
	Product Name	Windquest V707 Tilt Double Hung
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-05 AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E 1886; ASTM E 1996 Missile Level D

Impact Resistance:

Impact Resistant	Requirement
Yes	These products satisfy the Texas Department of Insurance's criteria for protection from windborne debris in the Inland I and Seaward zone . The assemblies may be installed at any height on the structure as long as the design pressure rating for the assemblies is not exceeded.

Installation (One of the Following):

Strap Installation: The wood wall framing members shall be minimum Spruce-Pine-Fir dimension lumber. The window shall be mounted to the wood wall framing members using galvanized steel straps (4.201" x 1.000" x 0.059"). The straps are snap-fit into the window frame. Each strap is secured to the wall framing with one (1) minimum No. 8 screw. The straps shall be located approximately 6 inches from each corner, approximately 12 ½ inches on center along the side jambs, and approximately 13 ½ inches on center along the head and sill. In addition, a strap shall be located at each side jamb approximately 3 inches and 7 ½ inches below the meeting rail and approximately 4 ½ inches and 7 ½ inches above the meeting rail. The fasteners shall be long enough to penetrate a minimum of 1 ½" into the wall framing members.

Frame Installation: The wood wall framing members shall be minimum Spruce-Pine-Fir dimension lumber. The window shall be mounted to the wood wall framing members using the frame of the window with minimum No. 8 screws. The fasteners shall be located approximately 6 inches from each corner, approximately 12 ½ inches on center along the side jambs, and approximately 13 ½ inches on center along the head and sill. In addition, a fastener shall be located at each side jamb approximately 3 inches and 7 ½ inches below the meeting rail and approximately 4 ½ inches and 7 ½ inches above the meeting rail. The fasteners shall be long enough to penetrate a minimum of 1 ½" into the wall framing members.

Note: The manufacturer's installation instructions shall be available on the job site during installation. All fasteners shall be corrosion resistant as specified in the International Residential Code (IRC), the International Building Code (IBC), and the Texas Revisions.